

VALEURS D'ISOLATION PHONIQUE

Sonocombidec 250

| Sonodec 250/Combidec 2100 (Test report Nr. AB323-3 Peutz bv - The Netherlands) | | | | | | | |
|--|----------|----------------------------------|-----|-----|------|------|------|
| D _n (mm) | L (m) | Atténuation dB - Mid-frequez, HZ | | | | | |
| | | 125 | 250 | 500 | 1000 | 2000 | 4000 |
| 80 | 1 | 11 | 12 | 22 | 33 | 37 | 20 |
| | 2 | 15 | 19 | 32 | 65 | 60 | 33 |
| 100 | 1 | 3 | 8 | 20 | 35 | 26 | 15 |
| | 2 | 5 | 13 | 32 | 67 | 42 | 23 |
| 125 | 1 | 4 | 8 | 17 | 29 | 23 | 17 |
| | 2 | 6 | 14 | 30 | 58 | 39 | 25 |
| 160 | 1 | 6 | 11 | 18 | 34 | 20 | 11 |
| | 2 | 10 | 18 | 34 | 59 | 27 | 18 |
| 200 | 1 | 1 | 4 | 10 | 20 | 8 | 8 |
| | 2 | 4 | 10 | 23 | 44 | 19 | 16 |
| 250 | 1 | 3 | 7 | 13 | 17 | 8 | 10 |
| | 2 | 5 | 11 | 23 | 35 | 14 | 14 |
| 315 | 1 | 4 | 6 | 12 | 16 | 7 | 8 |
| | 2 | 5 | 11 | 21 | 27 | 12 | 13 |
| 450 | 1 | 3 | 4 | 6 | 5 | 4 | 7 |
| | 2 | 9 | 11 | 14 | 10 | 9 | 10 |
| 500 | 1 | 2 | 5 | 10 | 7 | 5 | 6 |
| | 2 | 6 | 9 | 18 | 12 | 9 | 10 |

Ces valeurs d'isolation sont seulement valables pour les tuyaux mentionnés ci-dessus